### **2016 Consumer Confidence Report**

Water System Name:	Davenport C	County Sanitation District	Report Date:	6-15-17
_		any constituents as required by od of January 1 - December 31	-	
Este informe contiene in entienda bien.	nformación mu	uy importante sobre su agua j	potable. Tradúzcal	o ó hable con alguien que lo
Type of water source(s) is	n use: Stream	n		
Name & general location	of source(s):	Stream 1, 4400571-002 San V	incente Cr. Stream	2, 4400571-003 Mill Cr.
Drinking Water Source A	ssessment info	rmation: Available through t	he County of Santa C	Cruz Department of
Environmental Health			•	•
Time and place of regular	rly scheduled b	oard meetings for public partici	pation: Tuesdays a	at 701 Ocean Street
Santa Cruz, CA 95062				
For more information, con	ntact: Isaac Bo	ojorquez	Phone: (831)	477-3901

#### TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS)**: MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS)**: MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL)**: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Variances and Exemptions**: State Board permission to exceed an MCL or not comply with a treatment technique under certain conditions.

**ND**: not detectable at testing limit

**ppm**: parts per million or milligrams per liter (mg/L)

**ppb**: parts per billion or micrograms per liter ( $\mu$ g/L)

**ppt**: parts per trillion or nanograms per liter (ng/L)

**ppq**: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

### Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 7, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA									
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of months in violation		MCL		MCLG	Typical Source of Bacteria		
Total Coliform Bacteria (San Vicente) stream 1 (Mill Creek) stream 2	12 12	0		More than 1 sample in a month with a detection		0	Naturally present in the environment		
Fecal Coliform or E. coli (San Vicente) stream 1 (Mill Creek) stream 2	12 12	0		A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>		0	Human and animal fecal waste		
TABLE 2	TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER								
Lead and Copper (complete if lead or copper detected in the last sample set)	Sample Date	No. of samples collected	90 <sup>th</sup> percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant		
Lead (ppb)	11-17-16	10	ND	N/A	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits		
Copper (ppb)	11-17-16	10	ND	N/A	1300	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives		
	TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS								
Chemical or Constituent (and reporting units)	Sample Date	Level Detected		Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant		
Sodium (ppm) San Vicente Mill Creek	10-5-16	15 15		0.5	-		Salt present in the water and is generally naturally occurring		

Hardness (ppm)	10-5-16		5	-	Sum of polyvalent cations present
San Vicente		66			in the water, generally magnesium
Mill Creek		62			and calcium, and are usually
					naturally occurring

\*Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 4 – DET  Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminan
рН	10-5-16		0.1	-		Runoff/leaching from natural
San Vicente		7.7				deposits.
Mill Creek		7.7				
Specific Conductance (EC)	11-8-16		1.0	1600		Runoff/leaching from natural deposits.
San Vicente		190				
Mill Creek		190				
Hydroxide as OH	10-5-16		2.0	-		Runoff/leaching from natural
San Vicente		ND				deposits.
Mill Creek		ND				
Carbonate as CO3	10-5-16		2.0	-		Runoff/leaching from natural
San Vicente		ND				deposits.
Mill Creek		ND				
Bicarbonate as HCO3	10-5-16		2.0	-		Runoff/leaching from natural
San Vicente		0.2				deposits.
Mill Creek		92 80				
Total Alkalinity as CaCO3	10-5-16		2.0	-		Runoff/leaching from natural deposits.
San Vicente		76 66				
Mill Creek		00				
<b>Total Dissolved Solids</b>	10-5-16		10	1000		Runoff/leaching from natural
San Vicente		130				deposits.
Mill Creek		130				
Chloride	10-5-16		1.0	500		Runoff/leaching from natural
San Vicente		13				deposits.
Mill Creek		15				
Sulfate as SO4	10-5-16		1.0	500		Runoff/leaching from natural
San Vicente		9.5				deposits.
Mill Creek		13				
Fluoride	10-5-16		0.10	2		Runoff/leaching from natural
San Vicente		ND				deposits.
Mill Creek	<u> </u>	ND ND				
Calcium	10-5-16		0.50	-		Runoff/leaching from natural
San Vicente		19				deposits.
Mill Creek		20				
Magnesium	10-5-16		0.50	-		Runoff/leaching from natural
San Vicente		4.6				deposits.
Mill Creek		3.0				

Potassium	10-5-16		0.50	-	Runoff/leaching from natural
San Vicente		1.8			deposits.
Mill Creek		2.2			
Iron	10-5-16		50	300	Runoff/leaching from natural
San Vicente		NID			deposits.
Mill Creek		ND 80			
Manganese	10-5-16		20	50	Runoff/leaching from natural
San Vicente		ND			deposits.
Mill Creek		ND			
Copper	10-5-16		50	1000	Runoff/leaching from natural
San Vicente		ND			deposits.
Mill Creek		ND			
Zinc	10-5-16		50	5000	Runoff/leaching from natural
San Vicente		ND			deposits.
Mill Creek		ND			
Color	10-5-16		3.0	-	Runoff/leaching from natural
San Vicente		ND			deposits.
Mill Creek		4.0			
Threshold Odor No.	10-5-16		1.0	-	Runoff/leaching from natural
San Vicente		ND			deposits.
Mill Creek		ND			
Turbidity	10-5-16	·	0.10	_	Runoff/leaching from natural
San Vicente		0.11	0.10		deposits.
Mill Creek		0.84			
Nitrate as N	10-5-16		0.10	10	Runoff/leaching from natural
San Vicente		ND	0.10		deposits.
Mill Creek		0.35			
Volatile Organic	10-5-16	0.00	_	_	VOCs are contained in a wide
Chemicals (VOCs)					variety of commercial, industrial
EPA 524.2					and residential products including fuel oils, gasoline, solvents,
San Vicente		ND			cleaners and degreasers, paints,
Mill Creek		ND			inks, dyes, refrigerants and
		11,5			pesticides.
Nitrate + Nitrite as N	11-8-16		0.10	10	Runoff/leaching from natural deposits.
San Vicente		ND			deposits.
Mill Creek		0.36			
Arsenic	11-8-16		2.0	10	There are many sources of inorganic contamination. Some of
San Vicente		ND			it is man-made and some of it
Mill Creek		ND			occurs naturally.
Barium	11-8-16		100	1000	There are many sources of
San Vicente		ND			inorganic contamination. Some of it is man-made and some of it
Mill Creek		ND			occurs naturally.
Boron	11-8-16		100	-	There are many sources of
San Vicente		ND			inorganic contamination. Some of it is man-made and some of it
Mill Creek		ND			occurs naturally.

Cadmium	11-8-16		1.0	50	There are many sources of
San Vicente		ND			inorganic contamination. Some of it is man-made and some of it
Mill Creek		ND			occurs naturally.
Chromium	11-8-16		1.0	50	There are many sources of
San Vicente		ND			inorganic contamination. Some of it is man-made and some of it
Mill Creek		ND			occurs naturally.
Cyanide (Total)	11-8-16		100	200	There are many sources of
San Vicente		ND			inorganic contamination. Some of
Mill Creek		ND			it is man-made and some of it occurs naturally.
Lead	11-8-16		5	15	There are many sources of
San Vicente		ND			inorganic contamination. Some of
Mill Creek		ND			it is man-made and some of it occurs naturally.
Mercury	11-8-16		1.0	2	There are many sources of
San Vicente		ND			inorganic contamination. Some of
Mill Creek		ND			it is man-made and some of it occurs naturally.
Selenium	11-8-16		5	50	There are many sources of
San Vicente	11-0-10	ND		30	inorganic contamination. Some of
Mill Creek		ND			it is man-made and some of it occurs naturally.
Silver	11-8-16	ND	10	100	There are many sources of
San Vicente	11-6-10	ND	10	100	inorganic contamination. Some of
Mill Creek		ND ND			it is man-made and some of it
MBAS	11-8-16	ND	0.025	0.5	occurs naturally.  There are many sources of
-	11-8-10	ND	0.025	0.5	inorganic contamination. Some of
(Surfactant)		ND			it is man-made and some of it
San Vicente		ND			occurs naturally.
Mill Creek	11.016		50	1000	There are many sources of
Aluminum	11-8-16	N.D.	50	1000	inorganic contamination. Some of
San Vicente		ND			it is man-made and some of it
Mill Creek		ND	_	_	occurs naturally.  There are many sources of
Antimony	11-8-16		6	6	inorganic contamination. Some of
San Vicente		ND			it is man-made and some of it
Mill Creek		ND			occurs naturally.
Beryllium	11-8-16		1.0	4	There are many sources of inorganic contamination. Some of
San Vicente		ND			it is man-made and some of it
Mill Creek		ND			occurs naturally.
Nickel	11-8-16		10	100	There are many sources of inorganic contamination. Some of
San Vicente		ND			it is man-made and some of it
Mill Creek		ND			occurs naturally.
Thallium	11-8-16		1.0	2	There are many sources of
San Vicente		ND			inorganic contamination. Some of it is man-made and some of it
Mill Creek		ND			occurs naturally.
Nitrite as N	11-8-16		0.10	1.0	There are many sources of
San Vicente		ND			inorganic contamination. Some of it is man-made and some of it
Mill Creek		ND			occurs naturally.
Average Chlorine	1-1-16		-	-	Sodium Hypochlorite used for
Residual (mg/L)	through				disinfection.
Distribution System	12-31-16	3.3			

<b>Bromodichloromethane</b> Distribution System	11-8-16	16	1.0	-		Disinfectants can react with naturally-occurring materials in the water to form byproducts.
<b>Bromoform</b> Distribution System	11-8-16	ND	1.0	-		Disinfectants can react with naturally-occurring materials in the water to form byproducts.
Chloroform (Trichloromethane)	11-8-16		1.0	-		Disinfectants can react with naturally-occurring materials in the
Distribution System		56				water to form byproducts.
<b>Dibromochloromethane</b> Distribution System	11-8-16	3.5	1.0	-		Disinfectants can react with naturally-occurring materials in the water to form byproducts.
Total Trihalomethanes (TTHMs)	11-8-16		0.5	80		Disinfectants can react with naturally-occurring materials in the
Distribution System		76				water to form byproducts.
Monochloroacetic Acid (MCAA) Distribution System	11-8-16	ND	2.0	-		Disinfectants can react with naturally-occurring materials in the water to form byproducts.
Dichloroacetic Acid (DCAA) Distribution System	11-8-16	20	1.0	-		Disinfectants can react with naturally-occurring materials in th water to form byproducts.
Trichloroacetic Acid (TCAA) Distribution System	11-8-16	32	1.0	-		Disinfectants can react with naturally-occurring materials in th water to form byproducts.
Monobromoacetic Acid (MBAA) Distribution System	11-18-16	ND	1.0	-		Disinfectants can react with naturally-occurring materials in th water to form byproducts.
Dibromoacetic Acid (DBAA) Distribution System	11-8-16	ND	1.0	-		Disinfectants can react with naturally-occurring materials in th water to form byproducts.
Haloacetic Acids (five) (HAA5) Distribution System	11-8-16	52	-	60		Disinfectants can react with naturally-occurring materials in th water to form byproducts.
TABLE 5 – DETE	ECTION OF	CONTAMINA	NTS WITH A S	ECONDAR	<u>Y</u> DRINKIN	IG WATER STANDARD
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Perchlorate (ug/L)	11-8-16		2.0	6		Perchlorate is an inorganic
San Vicente Mill Creek		ND ND				chemical used in rocket propellant fireworks, flares, matches, and a variety of industries. It usually get into drinking water as a result of environmental contamination from historic aerospace or other industrial operations that used or use, store or dispose of perchlorate and its salts
Specific Conductance (umhos/cm) San Vicente	11-8-16	190	1.0	1600		Substances that form ions when in water, seawater influence
	1	190		1		1

Revised Jan 2016 2016 SWS CCR Form

Mill Creek

Turbidity (units)	1-1-16		-			Soil runoff	
Raw	Through	0.25 to 14.0		-			
Filtered	12-31-16	0.030		0.2000			
TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS							
					- ,	1-0	
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections		tion Level	Health Effects Language	
	Sample		Range of				

<sup>\*</sup>Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

### **Additional General Information on Drinking Water**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Davenport County Sanitation District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <a href="http://www.epa.gov/lead">http://www.epa.gov/lead</a>.

# Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT							
Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language			
N/A	-	-	-	-			

### For Water Systems Providing Ground Water as a Source of Drinking Water

TABLE 7 – SAMPLING RESULTS SHOWING FECAL INDICATOR-POSITIVE GROUND WATER SOURCE SAMPLES								
Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant			
E. coli	(0 In The Year)	-	-	-	Human and animal fecal waste.			
Enterococci	N/A	-	-	-	Human and animal fecal waste.			
Coliphage	N/A	-	-	-	Human and animal fecal waste.			

## Summary Information for Fecal Indicator-Positive Ground Water Source Samples, Uncorrected Significant Deficiencies, or Ground Water TT

SPECIAL	NOTICE OF FECAL IND	ICATOR-POSITIVE GR	OUND WATER SOURCE	SAMPLE
		N/A		
	SPECIAL NOTICE FOR	UNCORRECTED SIGNI	FICANT DEFICIENCIES	
		N/A		
	VIOLA	TION OF GROUND WA	TER TT	
TT Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
N/A	-	-	-	-

## For Systems Providing Surface Water as a Source of Drinking Water

TABLE 8 - SAMPLING RESULTS SHOWING TREATMENT OF SURFACE WATER SOURCES				
Treatment Technique <sup>(a)</sup> (Type of approved filtration technology used)				
Turbidity Performance Standards (b) (that must be met through the water treatment process)	Turbidity of the filtered water must:  1 – Be less than or equal to NTU in 95% of measurements in a month.  2 – Not exceed NTU for more than eight consecutive hours.  3 – Not exceed NTU at any time.			
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.				

Highest single turbidity measurement during the year	
Number of violations of any surface water treatment	
requirements	

### **Summary Information for Violation of a Surface Water TT**

VIOLATION OF A SURFACE WATER TT				
TT Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
N/A	-	-	-	-

	Summary Information for Operating Under a Variance or Exemption
_	

<sup>(</sup>a) A required process intended to reduce the level of a contaminant in drinking water.

<sup>(</sup>b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

<sup>\*</sup> Any violation of a TT is marked with an asterisk. Additional information regarding the violation is provided below.