

PRIVATE SANITARY SEWER LATERAL INSPECTION REPORT

Form to be completed by a **licensed plumber** and submitted to the County of Santa Cruz prior to any repair work, along with **copy of video** inspection (CD or USB drive). Video shall be clear, well lit, in color, traveling no more than 20ft/min & hold for minimum of 5 seconds at defects & joints/connections.

Customer's Name: _____ Property Address: _____ Phone: _____

Customer's Mailing Address: _____
Street Address City State Zip code

Company Name: _____

Email Address: _____ Inspector's Name: _____ Phone: _____

Contractor's License No.: _____ Pipe Size: _____ Pipe Material: _____

Sewer Usage: Residential (House/Mobile) School Other (Specify): _____
 Multi-Family (Condo/Apartment) Commercial

CCTV Date: _____ Time: _____ Camera Direction: With Flow Against Flow Total Length: _____

OBSERVATION CODES

B	BROKEN	I	INFILTRATION	OR	OUT OF ROUND	S	SAG	O	OFFSET
C	CRACK	CP	CHANGE IN PIPE	F	FRACTURE	R	ROOTS		


LATERAL INSPECTION LOG (Add additional sheets if necessary)

DISTANCE	OBSERVATION CODE	REMARKS (Including severity of defects)	COUNTY USE	
1.				
2.				
3.				
4.				
5.				
6.				
7.				
8.				

COMPLETE STANDARD DRAWING

OR

DRAW A CUSTOM SKETCH



Fill in the distances (to cleanout and lateral) and indicate street name and north direction.

Show distance from building to cleanout and cleanout to public sewer main. Also, please indicate street name(s), approximate property lines and north direction.

Please be sure to answer all of the questions below:

- Yes ___ No ___ Is cleanout accessible outside of building?
- Yes ___ No ___ Is there a sewer ejector pump at this property?
- Yes ___ No ___ Does private sewer lateral appear to cross neighboring private property?
- Yes ___ No ___ Does private sewer lateral connect to County sewer in public right of way?
- Yes ___ No ___ Is there more than one structure at this address served by the private sewer lateral?
- Yes ___ No ___ Does property have a backwater valve?
- Yes ___ No ___ If YES, is backwater valve functioning properly?
- Yes ___ No ___ If NO, does property require a backwater valve per Uniform Plumbing Code 710.1?
- Yes ___ No ___ Are there any outside drains connected to the sewer system?
- If none, how did you verify that there were no outside drains connected to the sewer system?
-

Please give professional opinion on the condition of the sanitary sewer lateral:

Please specify work recommended on the lateral, if any:

I certify that the information and video recording I have provided with this form are true and correct.

Inspector's/

Plumber's signature: _____ Date: _____ License # _____

COUNTY USE ONLY

COUNTY COMMENTS:

- STATUS: VIDEO RECEIVED VIDEO NOT RECEIVED LATERAL OK AS-IS REQUIRES WORK
- COPY TO: COUNTY OF SANTA CRUZ- SANITATION OWNER/SITE ADDRESS
- DISTRICT: SANTA CRUZ DAVENPORT FREEDOM