


**California Regional Water Quality Control Board, Central Coast Region
SEWAGE OVERFLOW REPORT**

PRIVATE ~ _____ (Check if Applies)

(Include all available details (use attachments as needed) - submit follow-up written reports as necessary)

Reporting Party	Santa Cruz County	Phone	(831) 477-3907
Discharger	SCCSD	Basin	Boulder Creek
Address	2750 Lode Street	City	Santa Cruz, CA 95062
Date of Overflow: 10/06/2009	Time Overflow Began: 4:00 pm	Time Overflow Stopped: 5:05 pm	
Responding Crew:	J Hurley, A Sandoval, J Vega, D Ortega, G Buri		
Location/Address of Overflow Origin	175 Fern Rock		
Volume of Overflow 25-50 gal	Path of Overflow: into gutter and dirt		
Water body/Bodies Affected:	NA		
Cause of Overflow:	Small crack in force main pipe		
Action Taken To Stop Overflow: Stop flow to FM. Repaired pipe 10/07/09			
Time Cleanup Began: NA		Time Cleanup Complete: NA	
Discussion Of Cleanup: NA			
Were Public Health Warnings Posted, And If So, Where? No		Number Of Overflows In Same Location In Last Three Years? Two	
Discussion Of Measures Taken To Prevent Overflows At This Time: Force main is scheduled to be replaced			
Agencies Notified: Name/Time/Dates:	Netcom: 1345 10/7/09 Ashley	County Envir. 1400 10/7/09 Message to J Ricker	
RWQCB:1347 7/7/09 message to M Higgins	County Board of Directors: Agenda date: _____	O.E.S.: 1350 10/7/09 Tim 09-6765	
Fish & Game: 1404 10/7/09	Monterey Bay National Marine Sanctuary:	U.S.C.G. Monterey:	
U.S.C.G. Spill Response Ctr:			
SIGNATURE/TITLE 		DATE OCT 8 2009	