

**California Regional Water Quality Control Board, Central Coast Region
SEWAGE OVERFLOW REPORT**

PRIVATE ~ _ _ (Check if Applies)

(Include all available details (use attachments as needed) - submit follow-up written reports as necessary)

Reporting Party	Santa Cruz County	Phone	(831) 477-3907
Discharger	SCCSD	Basin	Boulder Creek
Address	2750 Lode Street	City	Santa Cruz, CA 95062
Date of Overflow: 1/21/2010	Time Overflow Began: 0600	Time Overflow Stopped: 0730	
Responding Crew:	S St Denis, P James, P James		
Location/Address of Overflow Origin	Boulder Creek Treatment Plant		
Volume of Overflow 4500 gal	Path of flow: Into storm drain to creek		
Water body/Bodies Affected: Boulder Creek			
Cause of Overflow: Generator malfunction			
Action Taken To Stop Overflow: Restarted generator			
Time Cleanup Began: NA		Time Cleanup Completed: NA	
Discussion Of Cleanup: No cleanup due to heavy rains			
Were Public Health Warnings Posted, And If So, Where? NO		Number Of Overflows In Same Location In Last Three Years? 2	
Discussion Of Measures Taken To Prevent Overflows At This Time: None			
Agencies Notified: Name/Time/Dates:	Netcom: 1/21/10 0853 #300 Stephanie	County Envir. Health: 1/21/10 0900 Message for J Ricker	
RWQCB: 1/21/10 0855 Message for M Higgins	County Board of Directors: Agenda date: _____	O.E.S.: 1/21/10 0903 Patty 10-0515	
Fish & Game: 1/21/10 0910 Cathy Conway	Monterey Bay National Marine Sanctuary:	U.S.C.G. Monterey:	
U.S.C.G. Spill Response Ctr:	Other: 1/21/10 0850 S.C City Water Treatment Plant		
SIGNATURE/TITLE GARY DUBINSKY ASSISTANT SUPERINTENDENT		DATE January 22, 2010	